

# Teich-Aire KM SERIES COMPRESSOR

Operation &  
Maintenance  
Manual

# TABLE OF CONTENTS

Product Overview .....	2
Installation.....	3
Electrical.....	4
Operation.....	5
Maintenance.....	6
Troubleshooting.....	7
Warranty .....	8
Other Repairs .....	9
Repair Contact Form .....	10

# PRODUCT OVERVIEW

Thank you for purchasing this Teich-Aire rocking piston oil-less compressor. It is manufactured to the highest standards using quality materials. Please follow all recommended maintenance, operational, and safety instructions, and you will receive years of trouble-free service.

IMPORTANT: PLEASE READ THIS MANUAL AND SAVE FOR FUTURE REFERENCE.

Rocking Piston Compressor			
Model		Serial No.	
Air Flow	cfm	Max pressure	psi
Voltage	V	Hz	Amp
Phase	Single	Kw	RPM

To facilitate future technical assistance and/or parts orders, please copy the details from the compressor nameplate onto this page and save for future reference.

## Important Product Use Information

To avoid accidents, use only as described in this manual.

- Pump only clean, dry air.
- Operate at 32 °F – 104 °F (0 °C to 40 °C).
- Protect the unit from dirt and moisture.
- Do not pump flammable or explosive gases or use in an environment that contains such gases.
- Protect all surrounding items from exhaust air. Exhaust air can become very hot.
- Corrosive gases and particulate material will damage the unit. Keep free of any water vapor, oil-based contaminants, or other liquids.
- This pump is oil-less and requires no lubrication.

## Installation Requirements

Correct installation is your responsibility. Ensure proper installation conditions and installation clearances for sufficient airflow.

- Install the compressor in a clean, dry location.
- Ensure the compressor is protected from dirt, moisture, and harmful elements of the outdoor environment.
- Ambient air temperature (readings taken 4" away from any surface of the compressor) must not exceed 104 °F (40 °C).
- Ensure that adequate ventilation and cooling air (flowing across the compressor) is available to keep the compressor from overheating, which can cause premature damage.
- Mount the compressor to a stable, rigid operating surface. Using the provided shock mounts will reduce noise and vibration.
- Kasco offers a simple, durable bracket accessory that will allow you to easily mount the compressor to a wall, floor, or bench. Please contact your Kasco distributor and ask for the compressor mount kit appropriate for the voltage of your compressor (Part #771250 for 120V and Part #771260 for 240V).

### ⚠ WARNING



#### Electrical Shock Hazard

Disconnect electrical power at the circuit breaker or fuse box before installing this product.

Install this product where it will not come into contact with water or other liquids.

Install this product where it will be protected from harmful weather.

Electrically ground this product.

Failure to follow these instructions can result in fire, electrical shock, or death.

# INSTALLATION




## Plumbing

Remove plugs as necessary from the IN and OUT ports. Connect with pipe and fittings that are the same size or larger than the product's threaded ports. Be sure to connect the intake and exhaust plumbing to the correct inlet and outlet ports. Ports will not support plumbing.

Install the air filter in one inlet port. recommends installing a pressure relief valve in an outlet port to bleed off excess pressure in case of a blocked line. Check valves may be required to prevent back-flow through the compressor.



Compressors ship with fittings installed on some ports. Remove any red plastic inserts (no tools required). Make sure the threaded insert is installed on the IN port not in use. You may need to move it based on the plumbing shown below. Use an Allen wrench to remove the threaded insert and move it to the appropriate unused IN port.



# ELECTRICAL

Make sure that the power supply voltage agrees with that listed on the product nameplate. All cords with plugs must be plugged into an outlet that is properly installed and grounded in accordance with all local codes and ordinances. Hardwired installations must be connected to a grounded, metallic, permanent wiring system or an equipment grounding terminal or lead on the product.

It is your responsibility to contact a qualified electrician and assure that the electrical installation conforms with all national and local codes and ordinances. The metal capacitor located on the side of the compressor must be grounded.

## ⚠ WARNING



### Electrical Shock Hazard

This product must be properly grounded.

Do not modify the plug provided. If it will not fit the outlet, have the proper outlet installed by a qualified electrician.

If repair or replacement of the cord or plug is necessary, do not connect the grounding wire to either flat blade terminal. The wire with insulation that is green or green with yellow stripes is the grounding wire.

Check the condition of the power supply wiring. Do not permanently connect this product to wiring that is not in good condition or is inadequate for the requirements of this product.

Failure to follow these instructions can result in fire, electrical shock, or death.

# OPERATION

It is your responsibility to operate this compressor at recommended pressures and permissible ambient temperatures. Do not start against a vacuum or pressure load.

If the motor fails to start or slows down significantly under load, shut off and disconnect from the power supply. Check that the supply voltage is correct and verify that the motor is turning in the proper direction. Check the plug, cord, and switch for damage.

**WARNING:** Thermal protection switch may have tripped; the motor can restart automatically after cooling.

## WARNING

### Injury Hazard

Install proper safety guards as needed.

Keep fingers and objects away from openings and rotating parts.

When provided, motor terminal covers must be in place for safe operation.

Allow product surfaces to cool before handling. Product surfaces become very hot during operation.

Wear proper eye protection. Air stream from the product may contain solid or liquid material that can result in eye or skin damage.

Wear hearing protection. Sound level from motor may exceed 70 dBA.

Failure to follow these instructions can result in burns, eye injury, or other serious injury.

# MAINTENANCE

## ⚠ WARNING



### Electrical Shock Hazard

Disconnect electrical power supply cord before performing maintenance on this product.

If this product is hardwired into the system, disconnect electrical power at the circuit breaker or fuse box before performing maintenance.

Failure to follow these instructions can result in fire, electrical shock, or death.

## ⚠ WARNING

### Injury Hazard

Allow product surfaces to cool before handling. Product surfaces become very hot during operation.

Wear proper eye protection. Air stream from product may contain solid or liquid material that can result in eye or skin damage.

Clean this product in a well-ventilated area.

Failure to follow these instructions can result in burns, eye injury, or other serious injury.

It is your responsibility to:

- Regularly inspect and make necessary repairs to the compressor in order to maintain proper operations.
- Make sure that pressure is released from product before performing maintenance.

This compressor is oil-less and requires NO lubrication.

Check the intake filter after first 500 hours of operation.

Clean the filter and determine how frequently filters should be checked during future operation, being aware that environmental changes during different seasons can affect operation (heavy pollen in spring or increased dust particulate in a dry summer). Kasco recommends checking the filter every month. Clean or replace filter elements as necessary. This one procedure will help ensure the product's performance and service life. Failure to maintain clean air filter elements will lead to clogging, which will cause excessive heat and premature failure of the compressor.

Filter maintenance:

- Disconnect electrical power supply to unit.
- Vent all air lines.
- Remove filter cover.
- Remove and replace filter element as necessary.

# TROUBLESHOOTING

Low pressure	High pressure	Pump overheat	Will not start	Excess noise	Reason and solution for problem
✓		✓	✓		Filter is dirty. Clean or replace.
✓	✓	✓	✓		Muffler is dirty. Clean or replace.
✓					Valves are dirty or valves are bent. Clean or replace.
	✓	✓	✓		Relief valve is set too high. Inspect and adjust.
✓					Relief valve is set too low. Inspect and adjust.
✓	✓	✓	✓		Plugged pressure line. Inspect and repair.
		✓	✓		Low voltage, will not start. Check power supply.
		✓	✓	✓	Incorrect voltage. Check power supply.
✓				✓	Worn cup/piston hitting cylinder. Replace.
		✓		✓	Cylinder misadjustment. Realign.
✓			✓		Leaky hose or check valve. Replace.
✓		✓	✓	✓	Dirt or liquid on top of piston. Inspect and clean.
✓		✓	✓	✓	Motor not wired correctly. Check wiring diagram/line voltage.
✓				✓	Blown head gasket. Replace.



# WARRANTY

Warranty Period:

- Motor: 3 years
- Piston cups and cylinders: 2 years

Warranty is void if:

- The compressor is not maintained properly according to the maintenance recommendations supplied in this manual.
- The system is damaged by unauthorized tampering.



Please attach a repair form with the shipment. The repair form must include a name, physical address (for return delivery of the repaired unit), daytime phone number, and an e-mail address for correspondence regarding the warranty claim.

## OTHER REPAIRS

Most failed equipment can be repaired at substantially lower costs than replacement with new equipment. Please ship according to the instructions provided.

does estimates on repairs at the request of the customer. The request for an estimate should be included in the letter that accompanies the returned unit and must include a daytime phone number and/or email address. Estimate options are as follows:

- We will contact the customer with a total estimated cost for repairs after we have evaluated the unit but before we perform the work.
- We will repair the unit only if repair costs are under a dollar amount stated by the customer. Example: "Please repair if total is under \$150.00 before shipping charges."

All estimates that are rejected for repair will be destroyed unless otherwise directed by the customer. If the customer would like the unit returned, we will restore the unit as closely as possible to the condition in which we found it and ship at the customer's expense (including shipping and handling charges).

# REPAIR CONTACT FORM

- requires that all equipment sent for repair MUST be accompanied by this form and marked to Repairs attention.
- Unit should be cleaned before shipping.
- Kasco is NOT responsible for shipping damage accrued in return shipment.
- It is the responsibility of the customer to ship and pay freight to Kasco.

Note: Contact information should be that of the person or company to contact for repair information.

Company name			
Contact name	First name	Last name	
Address	Street		
	City		
	State		
	ZIP code		
Phone number	Primary	Alternate	
Email address			
Preferred method of contact (circle one)	Phone	Email	
Purchase order number			
Additional product information	Serial Number	Cord Length	
<b>Information for Repair Technician</b>			
Was this unit used in a chemical treatment or wastewater application? (circle one)		Yes	No
Additional notes			

**Postadress:**

TRÄDGÅRDSTEKNIK AB  
Helsingborgsvägen 578, Varalöv  
262 96 ÄNGELHOLM

Telefon : 0431-222 90  
Bg.nr : 5743-7980  
Org.nr : 556409-6120

**URL:**

[www.tradgardsteknik.se](http://www.tradgardsteknik.se)  
E-postadress:  
[info@tradgardsteknik.se](mailto:info@tradgardsteknik.se)